

Annual Drinking Water Quality Report LAKESIDE WATER DISTRICT IL0775150

Consumer Confidence Report

Annual Water Quality Report for the period of January 1 to December 31, 2017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by LAKESIDE WATER DISTRICT is Purchased Surface Water.

For more information regarding this report contact: Joel Snider Phone 618-457-5547

Lakeside Water District board meetings are the second Tuesday of the month.

Este informe contiene información muy sobre el agua que bebe. Tradúzcalo o hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-2791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by the office or call our water operator at 618-457-5547. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: CARBONDALE Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection. Primary sources in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion.

Source Water Information

Source Water Name	Type of Water	Report Status
CC01 - LAKESIDE WATER DISTRICT MASTER METERFF 0770150 TP03 -Carbondale Water, 1 Nutrition Plaza, Reed Station Road	SW	-----

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avq: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

2017 Regulated Contaminants Detected

	Disinfectants and Disinfection By- Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
		Chloramines	12/31/2017	2.3	1.8 - 3.0	MRDLG = 4	= 4	ppm	N
	Haloacetic Acids (HAA5)	2017	36	21.3 -38.2	No goal for the total	60	ppb	N	By-product of drinking water disinfection
	Total Trihalomethanes(TTHM)	2017	27	19.1 -21.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection
Lakeside Water District	Violations Table								
	Lead and Copper Rule								
	The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.								
	Violation Type	Violation Begin	Violation End	Violation Explained					
	None								
	Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
	Copper	7-14-2015	1.3	1.3	0.029	0	ppm	N	Erosion of natural deposits; leaching from wood preservatives; corrosion of household plumbing systems
	Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
	Copper	2017	1.3	1.3	0.0365	0	ppm	N	Erosion of natural deposits: Leaching from wood preservatives
	Lead	2017	0	15	1.22	0	ppb	N	Corrosion of household plumbing systems
Carbondale	Disinfectants and Disinfection By- Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
	Chloramines	12/31/2017	3	2.7 - 3.0	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes
	Haloacetic Acids (HAA5)	2017	41	22.6 -43.8	No goal for the total	60	ppb	N	By-product of drinking water disinfection
	Total Trihalomethanes (TTHM)	2017	30	18.8 -35.1	No goal for the total	80	ppb	N	By-product of drinking water disinfection

	Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
		Chloride	10/10/2017	7.0	7.0 - 7.0			ppm	N
	Magnesium	10/10/2017	2.9	2.9 - 2.9			ppm	N	Erosion of natural deposits
	Barium	10/10/2017	0.015	0.015 - 0.015	2.0	2.0	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
	Fluoride	10/10/2017	0.56	0.561 - 0.561	4.0	4.0	ppm	N	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer aluminum factories
	Manganese	10/10/2017	1.1	1.1 - 1.1	150.0	150.0	ppb	N	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.
	Nitrate (measured as Nitrogen)	4/4/2017	0.36	0.36 -0.36	10.0	10.0	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
	Sodium	10/10/2017	18.0	18.0 - 18.0			ppm	N	Erosion of naturally occurring deposits; Used in water softener regeneration.
	Sulfate	10/10/2017	22.0	22.0 - 22.0			ppm	N	Erosion of naturally occurring deposits; Used in water treatment.
Carbondale	Turbidity								
		Limit (Treatment)	Level Detected	Violation	Likely Source of Contamination				
	Highest Single measurement	1.0 NTU	0.21 NTU	N	Soil Runoff				
	Lowest monthly % meeting limit	0.3 NTU	100.00%	N	Soil Runoff				
Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We Monitor it because it is a good Indicator of water quality and the effectiveness of our filtrations system and disinfectants.									
Total Organic Carbon									
The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violation section									